

GRADATION ANALYSIS TEST REPORT
for Product: 02693/ 4/10 SINGLE SIZE GRAVEL

SAMPLE INFORMATION

Sample number **G DAT_10909_01BD**

Sampled/ tested
Mon 15 January 2018/ 22-01-18
at 0000 hrs

Location	-	Chainage/layer	-
Ticket/truck number	-	Weather conditions	-
Sampling notes	-	Aggregate type	-
Remarks 1	-	Remarks 2	-

SAMPLE ANALYSIS


Sieve size	Percent passing	Specification limits	Complies ?
20mm	100	100 - 100	yes
14mm	100	98 - 100	yes
10mm	99	85 - 100	yes
8mm	81	-	-
6.3mm	39	-	-
4mm	4	0 - 20	yes
2mm	1	0 - 5	yes
63µm	0.4	0.0 - 4.0	yes
Moisture content %	6.2	not specified	-
Flakiness index	no result	≤35	-
Chloride content %	no result	≤1.000	-

Parameters are evaluated to the accuracy of spec. limits

REMARKS

Compliance status ok
Category A of A-C includes secondary parameters

.....
.....
.....
.....
.....
.....
.....
.....
.....
.....
.....



GRADATION ANALYSIS TEST REPORT
for Product: 03333/ 10/20 SINGLE SIZE GRAVEL

SAMPLE INFORMATION

Sample number **GDAT_10903_01BD**
 Location -
 Ticket/truck number -
 Sampling notes -
 Remarks 1 -

Sampled/ tested
 Tue 09 January 2018/ 15:01:18
 at 0000 hrs

Chainage/layer -
 Weather conditions -
 Aggregate type -
 Remarks 2 -

SAMPLE ANALYSIS

Sieve size	Percent passing	Specification limits	Complies ?
40mm	100	100 - 100	yes
37.5mm	100	98 - 100	yes
20mm	96	85 - 100	yes
16mm	60	-	-
14mm	37	-	-
10mm	7	0 - 20	yes
4mm	0	0 - 5	yes
63µm	0	0 - 4	yes
Moisture content %	3.3	not specified	-
Flakiness index	no result	≤35	-

Parameters are evaluated to the accuracy of spec. limits.

REMARKS

Compliance status: ok
 Category A of A-C includes secondary parameters

.....

