GRADATION ANALYSIS TEST REPORT
for Product: 1200/ 10/20 Coarse Aggregate

Supplier/ source:

Material type: PD6682-2 Table 3 Gc85/20 Test method: Wash grading to BS EN 933-1:2012

SAMPLE INFORMATION

Sampled/ tested
Fri 20 November 2020/ 20 11 20
at 0830 hrs

Sample number **CLA_26188_F**

Customer	BGN PRODUCTION	Full Destination	Shierglas Stock
Ticket <> Truck Reg	-	SampCert <> Chainage	145238
Sampled by<>Operator	E. Boronczyk	Weather Conditions	Cloudy Chilly Still Dry
Retest Samp Nos Data	-	Logged by	E. Boronczyk

SAMPLE ANALYSIS

Sieve size	Percent passing	Specification limits	Complies ?
40mm	100	100 - 100	yes
31.5mm	100	98 - 100	yes
25mm	100	-	-
20mm	99	85 - 99	yes
16mm	73	-	-
14mm	42	-	-
12.5mm	18	-	-
10mm	6	0 - 20	yes
8mm	4	-	-
6.3mm	3	-	-
5mm	3	-	-
4mm	3	0 - 5	yes
500µm	2	-	-
63µm	2	-	-
Moisture content %	1.2	not specified	-
Flakiness index	11	<=35	yes

Parameters are evaluated to the accuracy of spec. limits

REMARKS

Compliance status ok
Category A of A-C excludes secondary parameters



Signed _____Laboratory Manager Print date 02 Mar 2021