

GRADATION ANALYSIS TEST REPORT
for Product: 03333/ 10/20 SINGLE SIZE GRAVEL
Supplier/ source:

Material type: Drystone aggregate Test method: Wash grading to BS EN 932-1: 1997

SAMPLE INFORMATION

Sampled/ tested
 Tue 09 January 2024/ 15-01-24
 at 0000 hrs

Sample number GDAT_12818_01BD

Location	-	Chainage/layer	-
Ticket/truck number	-	Weather conditions	-
Sampling notes	-	Aggregate type	-
Remarks 1	-	Remarks 2	-

SAMPLE ANALYSIS


Sieve size	Percent passing	Specification limits	Complies ?
40mm	100	100 - 100	yes
31.5mm	100	98 - 100	yes
20mm	96	85 - 100	yes
16mm	72	-	-
14mm	52	-	-
10mm	10	0 - 20	yes
4mm	3	0 - 5	yes
63µm	2	0 - 4	yes
Moisture content %	2.1	not specified	-
Uniformity coefficient	2	0 - 10	yes
Flakiness index	no result	<=35	-
Chloride content %	no result	<=10.000	-

Parameters are evaluated to the accuracy of spec. limits

REMARKS

Compliance status ok
 Category A of A-C includes secondary parameters

.....



Signed _____

Date ___/___/2024