


GRADATION ANALYSIS TEST REPORT



Product: Wayfarer
Material Code: BR04
 Supplied by: Breedon Quarry
 Customer:
 Site Address:
Material type: Proprietary / Limestone

Test method: BS EN 933-1:2012

Sample number	12484
Ticket No	
Sampled by	Roddis
Date Sampled	15/02/2021
Sample location	
Weather Conditions	



Sieve Size (mm)	Percent passing	Specification	Complies (Spec)
14		-	-
10	100	100 - 100	Yes
8	98	98 - 100	Yes
6.3	98	90 - 100	Yes
4	86	-	-
2.8	75	-	-
2	64	40 - 85	Yes
1	46	-	-
0.5	35	20 - 60	Yes
0.25	26	-	-
0.125	19	-	-
0.063	14.0	8.0 - 20.0	Yes
Moisture content (%)	6.0		

Sampled By:

Roddis

Tested By:

Smith

Date Tested:

16/02/2021