


GRADATION ANALYSIS TEST REPORT

Product: Golden Amber Gravel
Material Code: BR14
 Supplied by: Breedon Quarry
 Customer:
 Site Address:
 Material type: Proprietary / Limestone

 Test method: BS EN 933-1:2012



Sample number	34851
Ticket No	
Sampled by	Smith
Date Sampled	08/01/2024
Sample location	
Weather Conditions	



Sieve Size (mm)	Percent passing	Specification	Complies (Spec)
14	100	100 - 100	Yes
10	100	90 - 100	Yes
8	96	-	-
6.3	86	60 - 90	Yes
4	63	-	-
2.8	54	40 - 70	Yes
2	46	-	-
1	33	-	-
0.5	25	20 - 40	Yes
0.25	19	-	-
0.125	15	-	-
0.063	11.2	7.0 - 15.0	Yes
Moisture content (%)	5.0		

Sampled By:

Smith

Tested By:

Smith

Date Tested:

09/01/2024