


GRADATION ANALYSIS TEST REPORT

Product: 10/20mm Dolerite PSV60
Material Code: 70000059
Supplied by:
Testing Laboratory: National
Material type: HGS / Dolerite
Job Type: 100/General
Test Method (To BS EN 933): Splitting dry sample - no washing

Sampled to: BSEN 932-1 1997
Prepared to: BSEN 932-2 1997



Sample Information		Sieve Size (mm)	Percent passing	Spec	Complies
Sample number	AGG-21137	40	100	100	Yes
Sampled by	Sean Halstead	31.5	100	98 - 100	Yes
		20	97	85 - 100	Yes
		14	10	-	-
Date Sampled	17/02/2021	10	0	0 - 20	Yes
		4	0	0 - 5	Yes
Sample location	Stockpile	0.063	0.0	0 - 4.0	Yes

Moisture Content (%) **1.2**

Remarks

Signed:

Date Tested:

19/02/2021