


# GRADATION ANALYSIS TEST REPORT



**Product:** Wayfarer  
**Material Code:** BR04  
 Supplied by: Breedon Quarry  
 Customer:  
 Site Address:  
 Material type: Proprietary / Limestone  
  
 Test method: BS EN 933-1:2012

Sample number	34850
Ticket No	
Sampled by	Smith
Date Sampled	08/01/2024
Sample location	
Weather Conditions	



Sieve Size (mm)	Percent passing	Specification	Complies (Spec)
14		-	-
10	100	100 - 100	Yes
8	100	98 - 100	Yes
6.3	99	90 - 100	Yes
4	87	-	-
2.8	76	-	-
2	66	40 - 85	Yes
1	48	-	-
0.5	35	20 - 60	Yes
0.25	26	-	-
0.125	19	-	-
0.063	13.6	8.0 - 20.0	Yes
Moisture content (%)	6.8		